



Marley Eternit Ltd

Lichfield Road
 Branston, Burton-upon-Trent
 Staffordshire DE14 3HD
 Tel: 01283 722222 Fax: 01283 722290
 e-mail: roofinginfo@marleyeternit.co.uk
 website: www.marleyeternit.co.uk

**Agrément
 Certificate
 No 07/4415**

Designated by Government
 to issue
 European Technical
 Approvals

MARLEY ETERNIT DRY FIX ROOFING SYSTEMS

Système d'étanchéité pour toitures
 Bedachungsmaterialien

Product




• THIS CERTIFICATE REPLACES AND EXTENDS CERTIFICATE No 86/1646 AND RELATES TO MARLEY ETERNIT DRY FIX ROOFING SYSTEMS.

- The components of the system are described in the accompanying Detail Sheets.
- The systems are suitable for use as a substitute for conventional mortar bedding in conjunction with Marley Eternit's range of slates and tiles on new or existing pitched roofs.
- It is essential that the components of Marley Dry Fix Roofing Systems are used in accordance with the conditions set out in the Design Data and Installation sections of the Detail Sheets.

continued

Regulations — Detail Sheet 1

1 The Building Regulations 2000 (as amended) (England and Wales)

 The Secretary of State has agreed with the British Board of Agrément the aspects of performance to be used by the BBA in assessing the compliance of roofing components with the Building Regulations. In the opinion of the BBA, Marley Eternit Dry Fix Roofing Systems, if used in accordance with the provisions of this Certificate, will meet or contribute to meeting the relevant requirements.

Requirement: C2(b)

Resistance to moisture

Comment:

The systems meet this Requirement. See the *Weathertightness* section of the accompanying Detail Sheets.

Requirement: B4(2)

External fire spread

Comment:

The system meets this Requirement. See the *Properties in relation to fire* section of the accompanying Detail Sheets.

Requirement: Regulation 7

Materials and workmanship

Comment:

The systems are acceptable materials. See the tinted area in the *Durability* section of the accompanying Detail Sheets.

continued

These Front Sheets must be read in conjunction with the accompanying Detail Sheets, which provide information for specific systems.

2 The Building (Scotland) Regulations 2004 (as amended)



In the opinion of the BBA, Marley Eternit Dry Fix Roofing Systems, if used in accordance with the provisions of this Certificate, will satisfy, or contribute to satisfying, the various Regulations and related Mandatory Standards listed below.

Regulation:	8	Fitness and durability of materials and workmanship
Regulation:	8(1)	Fitness and durability of materials and workmanship
Comment:		The systems can contribute to a construction satisfying this Regulation. See the tinted area of the <i>Durability</i> section and the <i>Installation</i> part of the accompanying Detail Sheets.
Regulation:	9	Building standards — construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		The use of the systems will enable a roof to be unrestricted under this Standard, with reference to clauses 2.8.1 ⁽¹⁾⁽²⁾ and 2.8.2 ⁽¹⁾⁽²⁾ . See the tinted areas of the <i>Properties in relation to fire</i> section of the accompanying Detail Sheets.
Standard:	3.10	Precipitation
Comment:		The use of the systems will enable a roof to satisfy the requirements of this Standard, with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.6 ⁽¹⁾⁽²⁾ . See the tinted areas of the <i>Weathertightness</i> section of the accompanying Detail Sheets.
Regulation:	12	Building standards — conversions
Comment:		All comments given for these systems under Regulation 9, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).

3 The Building Regulations (Northern Ireland) 2000 (as amended)



In the opinion of the BBA, Marley Eternit Fix Dry Roofing Systems, if used in accordance with the provisions of this Certificate, will satisfy or contribute to satisfying the various Building Regulations as listed below.

Regulation:	B2	Fitness of materials and workmanship
Comment:		The systems are acceptable. See the tinted area in the <i>Durability</i> section of the accompanying Detail Sheets.
Regulation:	C4	Resistance to ground moisture and weather
Comment:		The systems meet this Regulation. See the <i>Weathertightness</i> section of the accompanying Detail Sheets.
Regulation:	E5	External fire spread
Comment:		The systems meet this Regulation. See the <i>Properties in relation to fire</i> section of the accompanying Detail Sheets.

4 Construction (Design and Management) Regulations 2007 Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See sections: 2 *Delivery and site handling* (2.1) of the relevant Detail Sheet and section 5 *Practicability of installation* of these Front Sheets.

5 Practicability of installation

Marley Eternit Dry Fix Roofing Systems are practicable to install using the method and design within the scope of this Certificate and in accordance with the manufacturer's instructions.

Conditions of Certification

6 Conditions

6.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is granted only to the company, firm or person named on the front page — no other company, firm or person may hold or claim any entitlement to this Certificate
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English law.

6.2 References in this Certificate to any Act of Parliament, Statutory Instrument, Directive or Regulation of the European Union, British, European or International Standard, Code of Practice, manufacturers' instructions or similar publication, are references to such publication in the form in which it was current at the date of this Certificate.

6.3 This Certificate will remain valid for an unlimited period provided that the product/system and the manufacture and/or fabrication including all related and relevant processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA

- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

6.4 In granting this Certificate, the BBA is not responsible for:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- individual installations of the product/system, including the nature, design, methods and workmanship of or related to the installation
- the actual works in which the product/system is installed, used and maintained, including the nature, design, methods and workmanship of such works.

6.5 Any information relating to the manufacture, supply, installation, use and maintenance of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used and maintained. It does not purport in any way to restate the requirements of the Health & Safety at Work etc Act 1974, or of any other statutory, common law or other duty which may exist at the date of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care. In granting this Certificate, the BBA does not accept responsibility to any person or body for any loss or damage, including personal injury, arising as a direct or indirect result of the manufacture, supply, installation, use and maintenance of this product/system.



In the opinion of the British Board of Agrément, Marley Eternit Dry Fix Roofing Systems are fit for their intended use provided they are installed, used and maintained as set out in this Certificate. Certificate No 07/4415 is accordingly awarded to Marley Eternit Ltd.

On behalf of the British Board of Agrément

Date of issue: 31st October 2007

Chief Executive

